PIMPRI CHINCHWAD MUNICIPAL CORPORATION, PIMPRI-18

FIRE DEPARTMENT

File No:- FB/GI/65/2026-27 Date:12/06/2026

FIRE SAFETY CERTIFICATE

Token No: 20261508 Token Date:02/06/2026

School Name: **CITY PRIDE SCHOOL, CHIKHALI - MOSHI.**

Address: **GAT NO. 112 & 113, DEHU - ALANDI ROAD, CHIKHALI - MOSHI, PUNE - 411062.**

Has Applied for Fire Safety Certificate

The Fire Officer has visited the school and inspected the Fire Protection System installed at the site. As per the technical remarks, this Fire Safety Certificate is being issued subject to compliance of the following conditions:

1. The entire fire protection system installed at the site should be maintained in excellent working condition for any fire emergency.
2. Fire extinguisher handling and operational training should be imparted to the teaching, non-teaching, and security staff of the school.
3. Testing, maintenance and refilling of all fire extinguishers / fire protection systems should be carried out by a competent person (Govt. Fire Licensed Agency). Form-B Certificate regarding the maintenance and operational condition of the Fire Fighting System should be submitted to the Fire Office as per Sec. 3(3) of the Fire Act 2016 every six months (January and July), failing which this certificate shall be treated as cancelled.
4. All static water tanks should be kept full for any fire emergency.
5. Fire / Emergency Evacuation Mock Drill should be carried out in the school once every six months.
6. All passages and corridors should be kept free from any obstructions and combustible material.
7. 'No Smoking Boards', 'Emergency Exit', 'Assembly Area' and 'Emergency Contact Numbers Boards' of Fire, Ambulance, Police, MSEB shall always be displayed in the school.
8. Fire protection systems (fire extinguishers) should be easily accessible, visible and maintained in good working condition.
9. A safety net should be installed in the staircase duct and school building construction site from the safety point of view.
10. This Fire Safety Certificate is issued only from the fire safety point of view and cannot be treated for any other purpose. Necessary permissions from statutory authorities should be obtained.
11. Construction of remaining floors of the school building is not permitted during school working hours.
12. All rules and regulations declared from time to time by PCMC or Government of Maharashtra shall be binding and any violation will be viewed seriously.
13. This School Operational (Utility) For Building - GP + 05 Floor & Height 20.25 Mtrs. With Net Built up area - 5746.57 Sq. mtrs & Gross Built up area 11482.56 Sq. mtrs. All terms and conditions mentioned in the above NOC must be strictly followed.
14. This Fire Safety Certificate is valid up to **Date:11/06/2027** only. Renewal should be done every year before the above mentioned date.

पिंपरी चिंचवड महानगरपालिका अग्निशामक विभाग पिंपरी, पुणे-४११०१८

Sub Fire Officer
Pimpri Chinchwad Municipal Corporation
Pimpri – 18

To,
The Principal
CITY PRIDE SCHOOL, CHIKHALI - MOSHI.
GAT NO. 112 & 113, DEHU-ALANDI ROAD, CHIKHALI- MOSHI, PUNE -411062.

Dr. [Mrs.] Ashwini Kulkarni
School Manager
City Pride School
Chikhali - Moshi, Pune - 411062

CITY PRIDE SCHOOL Affiliation 1131189

Mrs. Suja Rajesh
Principal
City Pride School
Chikhali - Moshi, Pune-411062